



#### MAST HEIGHT AND LOCATION

1. MASTS TALLER THAN 36 INCHES ABOVE ROOF SHALL BE GUYED.
2. THE LENGTH OF SERVICE DROP EXTENDING OVER ROOF (INCLUDING EAVES AND GUTTERS) SHALL NOT EXCEED 48 INCHES.
3. NEW METER PLACEMENTS SHALL BE APPROVED BY NEWNAN UTILITIES.

### TYPICAL STEEL SERVICE MAST INSTALLATION (FURNISHED AND INSTALLED BY CUSTOMER)